



COUNCIL FOR LEATHER EXPORTS

**Pre-Bid Meeting held on 8th February 2017 (Wednesday) at
CLE Head Office, Chennai**

Tender Notice No. CLE-HO/ASIDE/Madhavaram/2017/2 dated 31.1.2017

**Name of Work: *Appointment of Contractor for Capacity Augmentation of
Madhavaram CETP***

S.No.	REFERENCE	QUERIES	REPLY
1	Volume 2, Page 3, Clause 1.1 (Table)	Only 1 no. of Electro- magnetic flow meter is provided	The scope of the bidder is 1no. of Electro-magnetic flow meter
2	Volume 2, Page 10, Clause 1.7	Should Trolleys be included for Filter Press House	Provision of Trolleys are not in the scope of the contractor
3	Volume 2, Page 6, Clause 1.5	Are fine diffusers required?	Yes, Diffusers of 5 m ³ /hr per unit (upto 7.5 m ³ /hr per unit) is the requirement
4	Volume 2, Page 6, Clause 1.5	Shall we quote for sub-surface aerator?	No
5	Volume 1-A, Page 24, Annex 1, Clause 4.d	What should be the standard of treated effluent?	Except for TDS, all parameters should fulfill TNPCB standard
6	General	Any additional units / processes can be included ?	It is upto the contractor to have extra items. However their details should be included in technical as well as financial bid
7	Volume 2, Page 11	Dimension of Filter Press House	10 m x 3.5 m per Filter Press
8	General	Will there be space constraint for the new modules	Adequate space is available and bidders can check up the same during Site Visits.
9	Volume 1-B,	Disposal of Excavated Earth	Excavated Earth can be disposed

	Clause 27 & 84		within the premises of Madhavaram CETP
10	General	Should Drawings be provided with the bid	It should be completed during Detailed Engineering by the successful bidder. All approval for drawings should be made from contractor's expense.
11	Volume 2, Page 3	Can Floating mixers be provided, instead of submersible mixers. (since particles like Hair etc., may clog the mixer)	The CETP receives effluent primarily from 'Wet Blue to Finish' Tanneries. Moreover, the beneficiary is not satisfied with the efficiency of existing floating mixer
12	Volume 1-B, Clause 43 - 45	Clearance of Bills	The contractor shall raise the bill for the work done to the promoter. After verification and recommendation by beneficiary and ILIFO, the contractor will receive the payment from CLE.
13	Volume 1-B, Clause 92 & 93	Water and Power required for construction at free of cost	Water and Power shall be provided to the contractor at single point and they are chargeable against consumption
14	General	Water Proofing quantity not mentioned	They shall be included under 'Miscellaneous'
15	General	Soil bearing capacity test reports	The report shall be obtained during site visits.
16	General	Overall site layout drawing with dimensions	Shall be obtained during site visits
17	Volume 2, Clause 1.1-1.8	Make of local push buttons	Any BIS approved make
18	Volume 2, Clause 1.1-1.8	Make of Cables	Any BIS approved make, preferably Finolex
19	General	In case of amendment/ implementation of GST in Tamil Nadu, the price will vary accordingly	Taxes should be mentioned separately. The contractor shall be entitled to variation in tax structure.
20	Volume 3,	Mechanically cleaned bar screen	The new mechanical screen is to

	Page 5	details	be placed immediately after the existing manual screen. Space available may be verified during site visits.
21	Volume 3, Page 5	Quantity of Submersible Mixers	Totally 4 nos. required (2 nos. per compartment, there are two compartments)
22	Volume 3, Page 5	Raw Effluent Transfer Pumps for transferring raw effluent from receiving sump to two equalisation tank: no standby pumps considered	There are 2 pumps already (which are standby)
23	Volume 3, Page 5	Primary Flocculator mechanism for existing CETP module details	Tank dimension etc., may be verified during site visits
24	Volume 3, Page 5	Equalised effluent transfer quantity	Totally 4 nos. are required
25	Volume 3, Page 5	Make for Flash mixer mechanism	Bidder's own make
26	Volume 3, Page 5	Make for Mixers for Chemical Preparation Tank	Bidder's own make
27	Volume 3, Page 6	Diffused Aeration Systems: (i) number of air blowers required; (ii) whether VFD to be included for power consumption	(i) 3 numbers of air blowers is the requirement (ii) VFD is not to be included for power consumption
28	Volume 3, Page 6	Quantity of Filter Press	Totally 3 nos. of Filter Press are required
29	Volume 3, Page 6	Multigrade Filter – with autoback wash provision	Additionally time based back wash should be provided
30	Volume 3, Page 6	Treated water transfer pumps with control systems: Either Hydro-pneumatic system or by level operated system	Level operated system
31	Volume 2, Page 12	Treated effluent Collection tank Volume is 400 m ³ or 200 m ³	Totally 400 m ³ (200 m ³ x 2)
32	Volume 2, Page 9	Blower House (i) RCC or Shed to be confirmed	(i) RCC is required (ii) They shall be included under 'Miscellaneous'

		(ii) Not included in BOQ	
33	Volume 2, Page 11	Sludge holding Tank – not included in BOQ	They shall be included under ‘Miscellaneous’
34	Volume 3, Page 5	Lime Dosing Pumps Quantity	Total of 3 nos. are required

The following issues and clarification were also addressed to the bidders based on the queries raised by the representatives.

1. All the bidders were advised to keep the Earnest Money Deposit (EMD) in the form of Demand Draft only drawn from public sector or scheduled bank. This EMD should be kept in Cover 1 along with Technical Bid Documents. Therefore keeping the EMD by mistake in Cover 2- Financial Bid shall be a disqualification.
2. Letter authorising the representative (other than Director/Partner) should be provided in the bid.
3. It was also informed to the bidders that there shall be Main Cover in which Cover 1 – Technical Bids along with EMD duly sealed and Cover 2 - Financial Bid original duly sealed shall be submitted before the deadline at CLE Head Office, Chennai duly signed in all pages affixing the seal of the company / firm with authorized signatory.
4. Based on the request received from several bidders, the dead line for tender submission is now extended up to 23rd February 2017 3.00 PM. The technical bid will be opened on 23rd February 2017 at 3.30 PM. However, there is no change on sale of tender document. Tender sale shall be closed on 14th February 2017 as mentioned in the NIT.
